

HEAVY ENGINEERING CORPORATION LIMITED

(Fire Service/FFP)

No.FF/Fire/Audit/2022-57

Dated: 01.08.2022

Sub : **Inspection of Fire Safety establishment in D.A.V Public School,
Dhurwa, Ranchi.**

Ref : DAV/2022-23/165, Dtd- 13.07.2022

With reference to above the subject, Asstt. Manager I/c (Fire)/FFP inspected school premises on date- 29.07.2022.

During inspection at school premises and observed the occupancy is follow the guidelines of National Building Code (Part-4) under Group-C type of Institutional occupancy of Building area in respect of aforesaid school is 8094 sq.m. with 40 different types of Rooms such as Classroom, Offices, Practical Room etc. In said premises First-Aid-Fire fighting equipment has been attached which is stated as below.

- i) A.B.C TYPE OF Extinguisher (4kg.) -02 Pcs.
- ii) A.B.C TYPE OF Extinguisher (5kg.) -17 Pcs.
- iii) A.B.C TYPE OF Extinguisher (6kg.) -02 Pcs.
- iv) D.C.P TYPE OF Extinguisher (5kg.) -01 Pcs.

All Extinguisher is under IS- 15683 which is maintained by IS-2190 Norms, which is effected from May, 2022 for a period of May, 2023 in accordance with rule and subject to compliance of the conditions.

Ravindra Kumar
01/08/2022
(Ravindra Kumar)

Asstt. Manager, I/c(Fire)/FFP

Ravindra Kumar
Asst. Manager (Fire)
F.F.P., H.E.C. Ltd.
Ranchi-4